
#### PRODUCT INTRODUCTION

The product is high stability curtain PIRdetector. It has adopted advanced technology in signal processing and provided superhigh detection ability and anti error alarm. The detector will detect movement of human automatically when intruder passes through the detection area. The product is suitable for the safety of residential house, villas, factories, markets, warehouses, office building etc.

#### **PRODUCT PROFILE**



- 1 Wire exit
- 2 Wire contact
- 3 Delay
- 4 Relay jumper
- **5** Infrared sensor
- 6 Anti-dismantle switch
- 1 LED jumper
- 8 Thermistor resistance
- 9 Pluse jumper
- 10 PCB
- 1 LED indicator

### MAIN FEATURE

- Intelligent logic control, anti false alarm efficiently
- Auto temperature compensation
- Pulse count adjustment
- Anti white light interference
- Anti RF interference (20V/m~1GHz)
- Fresnel lens
- Wall/ceiling installation
- Alarm output N.C. / N.O. Optional

### TECHNICAL SPECIFICATION

Operating voltage:DC 9-16V

Alarm current: ≤18mA (D.C.12V)s

Detecting distance: wall mounted 9m; ceiling mounted 6m

Detecting angle: 15°

Self-testing time: about 60S

Radio distance: more than 100m (open area)

Alarm indicator: red LED

Alarm output: N.C./N.O. Optional,contact D.C.28V 100mA Anti-dismantle output: N.C., Contact D.C.28V 100mA

Sensor: dual element infrared sensor Operating temperature:  $-10^{\circ}\text{C} \sim +50^{\circ}\text{C}$ 

Environment humidity: ≤ 95% RH (no congelation)

Anti RF interference: 10MHz−1GHz 20V/m

Installation mode: wall / ceiling mounted

Installation height: 1.7 to 2.5m (wall mounted,2.2m is

Proposed); 2.5 to 6 m(ceiling mounted)

Outline Size: 69.5L\*40W\*110H mm


#### **INSTALLATION**

- Installation at the out door, place with pets, air-condition nearby, direct sunshine, heat source and under the rotating objects should be avoided.
- 2. Surface of installation should be firm with no vibration.
- 3. Installing the detector in the place where intruder pass easily.

### INSTALLATION STEP

- 1. Install the bracket on suitable position.
- 2. Open the front housing, and remove the PCB.
- 3. Fix the rear housing onto the bracket.
- 4. Fix the PCB, then install batteries.
- 5. Set the alarm direction to point out the inside.
- 6. Install the front housing.

### TERMINAL BLOCK FIGTURE



+12V DV ANODE
GND DV CATHODE
ALARM ALARM OUTPUT PORT
TAMPER ANTI-TEMPER OUTPUT PORT

### **OPERATING INSTRUCTION**

### Function Setting

1. Relay Jumper: Short N.C. or N.O. to set the state of alarm output. You should choose different alarm output in accordance with alarm host.

Short 1&2: N.O.

1

Short 2&3: N.C. (Default mode)

# MANUAL FOR CURTAIN PIR DETECTOR

Pulse Jumper: You can adjust the sensitivity and anti RF interference by choosing the Pulse Jumper.

Short 1&2: class 1 pulse, the sensitivity and anti RF interference is general, adapt to general environment.

Short 2&3: class 2 pulse, the sensitivity is highest, and anti RF interference is high, adapt to the environment with strong RF interference.

Shut off: class 3 pulse, the sensitivity is low, and the anti RF interference is highest, adapt to the environment with exceeding RF interference.

 LED Jumper: Control LED indicator, no effect of detector normal work.

Short 1&2: set LED ON

Short 2&3: set LED OFF
LED can be shut off for concealment of the detector after

Test.


## **Product testing**

Turning on power and LED indicator on, the detector comes into the state of self-check, it takes about 60s, after that it is in the state of normal work. Conner should walk parallel with the wall installed detector in the testing area. LED lighting means the detector is in the state of alarm.


## NOTICE

- Please install and use the detector according to this
  manual, don't touch the surface of sensor for avoiding
  affecting the sensitivity of the detector. Please shut off
  power and then clean the sensor by soft cloth with little
  alcohol if cleaning needed.
- 2. The product can reduce accident but may not perform as expected. The user is advised to take all necessary precautions for his/her safety and the protection of his/her property.
- 3. In order to ensure it can work normally, the power should be kept to supply and get on walking test periodically, once a week is better.

# JUMPER SETTING FIGURE



# **Detecting Area View**



Side View (wall mounted)



Top View (wall mounted)

